

**GOVERNMENT OF INDIA  
POWER  
LOK SABHA**

UNSTARRED QUESTION NO:1592  
ANSWERED ON:31.07.2003  
GENERATION OF POWER IN RAICHUR THERMAL POWER PLANT  
PUTTASWAMY GOWDA

**Will the Minister of POWER be pleased to state:**

- (a) whether power generation at the Raichur Thermal Power Plant Unit-2 has been stopped since long;
- (b) if so, the details thereof and the reasons therefor; and
- (c) the probable date of re-commencement of power generation in the Power Plant Unit-2?

**Answer**

THE MINISTER OF STATE IN THE MINISTRY OF POWER ( SHRIMATI JAYAWANTI MEHTA )

(a) : Yes, Sir.

(b) : Raichur Thermal Power Station Unit-2 (210 MW) of Karnataka Power Corporation Limited (KPCL) tripped on 1st June, 2003 at 22.00 hours due to the stator earth fault.

(c) : As ascertained from KPCL, the unit is expected to be recommissioned by 2nd week of August, 2003.